



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

December 29, 2011

Village of Greenfield  
Attn: Ms. Betty Bishop,  
300 Jefferson Street  
Greenfield, OH 45123

**Re: Greenfield WWTP- 1PD00022\*HD  
Notice of Violation**

Dear Ms. Bishop:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on December 14, 2011. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at [Joshua.Jackson@epa.state.oh.us](mailto:Joshua.Jackson@epa.state.oh.us).

Respectfully,

Joshua Jackson  
Environmental Specialist II  
Division of Surface Water

Ec: Jim McCoy, Village of Greenfield ([greenfield\\_wwtp@frontier.com](mailto:greenfield_wwtp@frontier.com))



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

**Notice of Violation Report**

---

**Facility:** Greenfield WWTP

**Permit No.:** 1PD00022\*HD

**Report Period:** November 2011

**Date Received:** 12/14/2011

| Station | Type  | Date       | Reporting Code | Parameter        | Limit Type  | Permit Limit | Reported Value |
|---------|-------|------------|----------------|------------------|-------------|--------------|----------------|
| 001     | Limit | 11/22/2011 | 00300          | Dissolved Oxygen | Daily Conc. | 6.0          | 5.9            |