



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

December 29, 2011

Metropolitan Sewer District of Greater Cincinnati  
Attn: Mr. Don Linn  
1600 Gest Street  
Cincinnati, OH 45204

**Re: Sycamore Creek WWTP- 1PK00005\*KD  
Notice of Violation**

Dear Mr. Linn:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on December 14, 2011. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at [Joshua.Jackson@epa.state.oh.us](mailto:Joshua.Jackson@epa.state.oh.us).

Respectfully,

Joshua Jackson  
Environmental Specialist II  
Division of Surface Water

Ec: Dave Wilson, MSDGC ([dave.wilson@cincinnati-oh.gov](mailto:dave.wilson@cincinnati-oh.gov))



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

**Notice of Violation Report**

---

**Facility:** Sycamore Creek WWTP

**Permit No.:** 1PK00005\*KD

**Report Period:** November 2011

**Date Received:** 12/14/2011

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
003	Limit	11/1/2011	00530	Total Suspended Solids	Monthly Load	443	645.207
003	Limit	11/22/2011	00530	Total Suspended Solids	Weekly Conc.	20	24.2857
003	Limit	11/22/2011	00530	Total Suspended Solids	Weekly Load	682	2084.09