



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

November 21, 2011

Darke County Commissioners  
County Administration Building  
520 South Broadway  
Greenville, OH 45331

**RE: NOTICE OF VIOLATION – Darke County Commissioners WWTPs  
Compliance Evaluation Inspections (CEIs)  
Rolin Acres WWTP, 1PG00090\*CD/OH0085561  
Stillwater Golf Estates WWTP, 1PX00014\*CD/OH0119067  
Darke County Home WWTP, 1PG00105\*BD/OH0133612  
Darke County Jail WWTP, 1PG00104\*BD/OH0133621**

Ladies and Gentlemen:

On November 1, 2011, I conducted Compliance Evaluation Inspections at the four package wastewater treatment plants operated by the Darke County Commissioners. These inspections were conducted to evaluate performance of the wastewater treatment facilities and compliance with respective NPDES permits. Bill Marker, Operator of Record, accompanied me on these inspections.

Detailed inspection reports are attached for each of the facilities along with a listing of effluent limitation violations reported for each of the facilities.

Provide a response to the **"ITEMS REQUIRING A RESPONSE"** section in the inspection report by **December 21, 2011**. If you have any questions, I can be reached at (937) 285-6109.

Sincerely,

Joe Miller  
Division of Surface Water

ec: William Marker, Operator of Record  
Darke County Health Department

**Darke County Commissioners  
Wastewater Treatment Plant Inspections  
November 1, 2011**

**ITEMS REQUIRING A RESPONSE**

1. **Disinfection Violations** – Effluent limitation violations related to disinfection were reported for all four wastewater treatment facilities. The current means of wastewater disinfection in all four facilities is tablet chlorination and tablet dechlorination. Tablets clogging and difficulty balancing the chemicals were reasons cited for these violations. Installation of in-pipe ultraviolet disinfection is strongly recommended for these facilities to avoid continued effluent limitation violations.
  
2. **Inflow and Infiltration** – The following is an excerpt from the May 2011 Rolin Acres Inspection. A response was not received to this item. Provide the requested plan for the Rolin Acres facility.
  - i. **Excessive Infiltration and Inflow** – *Reported flows were as high as five times the design flow of the wastewater treatment plant. High flows contribute to effluent limitation violations. While this has been a longstanding issue with this facility, substantive improvements have not been completed to remedy the situation. Provide a detailed plan with a proposed date for submittal of a Permit to Install for equalization of influent.*
  
3. **pH Meter** – Currently pH testing is being sent to the contract laboratory for testing on each of the wastewater facilities. Purchasing a pH meter, allowing the operator to take required samples for all facilities along with the ability to troubleshoot treatment components, is recommended.
  
4. **Sand Filter Media** – The sand filter media needs to be replaced in the sand filters in the County Jail, County Home, Stillwater Golf Estates, and the East sand filter at Rolin Acres. Provide a schedule for replacement.
  
5. **Sand Filter Walls** – The sand filter walls at the County Home and County Jail are in poor condition, with exposed rebar and cracks allowing leakage. Repair and patch the sand filter walls.

6. **Effluent Violations** – Detail the reasons for the listed violations. Your response should include dates, either actual or proposed, for completion of actions to prevent future violations. ***Non-compliance notification is required for all violations as detailed in the NPDES permit, Part III, Item 12. Any future incidences must be reported in this manner.***
7. **Skimmer at Stillwater Golf Estates** – The skimmer on the south side of the treatment plant is too high and needs to be adjusted.
8. **Clarifier Maintenance** – Overall maintenance of wastewater plant clarifiers needs to be improved. Algae and sludge deposits were observed in the effluent weirs. Sludge wasting frequency may need to be increased along with clarifier weir cleaning.

## OVERVIEW

The Darke County Commissioners own and operate four small extended aeration treatment plants. These facilities are located at the Rolin Acres Subdivision, Stillwater Golf Estates, the Darke County Home, and the Darke County Jail. The average design flow and average daily flow rates are as follows:

WWTP Facility	Average Design Flow	Average Daily Flow
Rolin Acres Subdivision	24,000 GPD	17,600 GPD
Stillwater Golf Estates	7,500 GPD	7,170 GPD
Darke County Home	10,000 GPD	7,993 GPD
Darke County Jail	10,000 GPD	2,183 GPD

Bill Marker is the Wastewater Operator or Record for these facilities. In addition, he will be the Operator of Record for the recently completed Osgood-North Star-Yorkshire regional treatment facility. He also monitors the Rossburg lift station at Ansonia for the county.

Infiltration and Inflow has been a problem in both the Stillwater Golf Estates and Rolin Acres Subdivision wastewater treatment collection systems. During periods of heavy storm flows, flows to the wastewater treatment exceed plant design resulting in the washout of solids to the sand filters and effluent limitation violations.

The Darke County Home and Darke County Jail are both located less than a mile from the City of Greenville's sanitary sewer collection system. The sewer is located along State Route 49 to the north. A number of businesses and residences are located along State Route 49 between the County properties and the sanitary sewer that have old or failing on-site septic systems. A sewer project to connect the County properties and the properties along State Route 49 would correct the conditions and eliminate the need for NPDES permits and monitoring.

Permit #: 1PX00014\*CD  
 NPDES #: OH0119067





State of Ohio Environmental Protection Agency  
 Southwest District Office

NPDES Compliance Inspection Report  
 Semi-Public Sewage Disposal Inspection Form

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PX00014*CD	OH0119067	11/1/2011	C	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Stillwater Golf Estates WWTP Lot 24, Stillwater Drive Versailles, OH 45380	2:30 PM	January 1, 2008
	Exit Time	Permit Expiration Date
	3:00 PM	December 31, 2012
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Bill Marker	937-459-2317	
Name(s), Address and Title(s) of Operator of Record	Phone Number(s)	
Bill Marker	937-459-2317	
Name, Address and Title of Responsible Official	Phone Number	
Darke County Commissioners County Administration Building 520 South Broadway Greenville, OH 45331	937-547-7370	

Ohio EPA Inspector	Ohio EPA Reviewer
 Joe Miller Division of Surface Water Southwest District Office	 Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office
11/22/11 Date	11/22/11 Date

Permit # : 1PX00014\*CD  
 NPDES #: OH0119067

Average Daily Design Flow:	7,500 Gallons/Day
Plant Serves:	Golf Course Community
Average Daily Flow: (Period of Review):	7,170 GPD (September 2010 to September 2011)
Method of flow monitoring:	Dosing
Type of alarms for plant:	Visual

**Pretreatment**

Type of Pretreatment: **Trash Trap**  
 Does the Trash Trap need pumped: **No**  
 Maintenance of pretreatment components is: **Satisfactory**

**Comments/Status:**

Trash trap pumped in October 2011. 1500 gallon tank.

**Secondary Treatment  
(Aeration)**

Color of sludge: **Unknown**  
 Quality of Sludge: **Unknown**  
 Foam: **Unknown**  
 Odor: **None**

	Yes	No		Yes	No
Aeration is taking place	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Plant is septic	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Blowers are operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Blowers are on a timer	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Skimmers are operating	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Plant is flooded	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Diffusers are operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Grating is present	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Sludge return is operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>			

Maintenance of aerating equipment is... **Unknown**

**Comments/Status:**

Duplicate blowers under same housing. Skimmer set too high on south side, adjust for proper skimming.

**Secondary Treatment  
(Settling)**

Clarity: **Solids Present**  
 Condition of Weir: **Excessive Algae/Solids Build Up**  
 Weir is level: **Unknown**  
 Effluent in weir: **Other**  
 Clarifier walls need scraped: **Yes**

Overall maintenance of settling components is: **Poor**

**Comments/Status:**

Sludge needs to be wasted. Algae and solids in weir, needs to be cleaned.

**Tertiary Treatment**

	Yes	No		Yes	No
Surface sand Filters: <b>Slow</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<b>Subsurface</b>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Distribution box operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Beds alternated	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Are filters ponding/flooding	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Beds raked	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Sand filters overgrown	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Chlorination present	<input type="checkbox"/>	<input checked="" type="checkbox"/>
UV present	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Dechlorination present	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Overall maintenance of components is: **Satisfactory**

**Comments/Status:**

Sand filter needs to have sand replenished/replaced. Remove leaves and solids from filters. Disinfection not required in November. Dosing pump alarmed.

**Sludge Handling/Storage Disposal**

Hauler name: Mike's Sanitation  
 Disposal Site: Mike's Sanitation Disposal Facility  
 Sludge wasted from: Sludge Holding

Sludge drying beds: **No**                      Sludge holding tank: **Yes**

Overall maintenance of components is: **Satisfactory**

**Comments/Status:**

1,000 gallons of sludge hauled in October 2011.

**Plant Discharge**

Discharge point is: **unnamed tributary**  
 Name of discharge point: **unnamed tributary of the Stillwater River**  
 Discharge is visible: **Yes**                      Quality of Effluent: **Clear**

**Comments/Status:**

Very little discharge at the time of inspection

**Stillwater Golf Estates WWTP Limitation Violations September 2010 to September 2011**

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2011	Total Suspended Solids	30D Qty	0.35	.77167	3/1/2011
March 2011	Total Suspended Solids	7D Qty	0.52	.77167	3/8/2011
April 2011	Total Suspended Solids	30D Qty	0.35	1.13323	4/1/2011
April 2011	Total Suspended Solids	7D Qty	0.52	1.13323	4/1/2011
April 2011	CBOD 5 day	30D Qty	0.29	.6365	4/1/2011
April 2011	CBOD 5 day	7D Qty	0.43	.6365	4/1/2011
May 2011	Nitrogen, Ammonia (NH3)	30D Conc	1.0	2.27	5/1/2011

Permit # : 1PX00014\*CD  
NPDES #: OH0119067

May 2011	Nitrogen, Ammonia (NH3)	30D Qty	0.03	.058	5/1/2011
May 2011	Fecal Coliform	30D Conc	1000	9500.	5/1/2011
May 2011	Nitrogen, Ammonia (NH3)	7D Conc	1.5	2.27	5/8/2011
May 2011	Nitrogen, Ammonia (NH3)	7D Qty	0.04	.058	5/8/2011
May 2011	Fecal Coliform	7D Conc	2000	9500.	5/8/2011
May 2011	Chlorine, Total Residual	1D Conc	0.019	.0634	5/12/2011
June 2011	Chlorine, Total Residual	1D Conc	0.019	.05	6/7/2011
July 2011	Fecal Coliform	30D Conc	1000	4800.	7/1/2011
July 2011	Fecal Coliform	7D Conc	2000	4800.	7/1/2011
September 2011	Chlorine, Total Residual	1D Conc	0.019	.124	9/6/2011

# Stillwater Golf Estates Flow September 2010 to September 2011

