



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

RE: Crawford County
Ranchwood MHP
NPDES Permit

December 29, 2011

Mr. Michael Yoh
4318 East Laurel Ridge Drive
Port Clinton, Ohio 43452

Dear Mr. Yoh:

On December 12, 2011, an inspection was made of the wastewater treatment facilities serving the Ranchwood Mobile Home Park, located on Lincoln Highway just east of the Crawford County Landfill.

At the time of inspection, the plant was locked providing proper security. The plant was running, but the aeration tanks and clarifier were not able to be evaluated from outside the fence. The west sand filter had solids in it and was ponded. There was sludge observed piled on the south side of the filters. Please note that this is not an acceptable way to handle sludge removed from the sand filters. When removed from the filters, the sludge should be bagged, weighed and disposed of in a landfill or dumpster.

A review of your discharge monitoring reports for the months of January 2011 through October 2011 indicates one E.Coli violation on July 1, 2011.

If you have any questions, please call me at 419-373-3019.

Sincerely,

Michelle Sharp
Environmental Specialist II
Division of Surface Water

/jlm

pc: John S. Kincaid, Kincaid Wastewater Services
Crawford County Health Department

ec: Inspection Tracking