



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

December 20, 2011

RE: CITY CENTER PARK
PERMIT NO. 3GC03527*AG
AURORA
PORTAGE COUNTY

Jim Kraus
Parks and Recreation Manager
City of Aurora
129 West Pioneer Trail
Aurora, Ohio 44202

Dear Mr. Kraus:

On December 16, 2011, this writer inspected the above referenced site. The purpose of the inspection was to observe the installation of the post construction retrofit for the existing sedimentation pond. The retrofit consists of the insertion of a 6-inch pipe inside the outlet structure. The outlet of the pipe is capped and a 2-inch diameter hole drilled to allow water to pass. This is in accordance with the approved Storm Water Pollution Prevention Plan (SWPPP) and is acceptable to this office.

If you should have any questions concerning any of the above, feel free to contact this writer at (330) 963-1136 or by e-mail at phil.rhodes@epa.state.oh.us.

Sincerely,

Philip Rhodes, PE
Environmental Specialist II
Division of Surface Water

PR/cs

cc: Kristopher Weiss, Ohio EPA, PIC, CO
Justin Czekaj, City Engineer, City of Aurora

File: Portage County, City of Aurora