



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

December 9, 2011

**RE: WAYNE COUNTY
CITY OF ORRVILLE
JM SMUCKER – DISCOVERY BUILDING
CONSTRUCTION STORM WATER**

Aaron Thompson
Domokur Architects
4651 Medina Rd.
Akron, OH 44321-1315

Rob Misutka
The JM Smucker Co
1 Strawberry Lane
Orrville, OH 44667

Dear Mr. Thompson and Mr. Misutka:

On December 8, 2011, Domokur Architects submitted calculations for the post-construction design of Detention Basin 3 at the above referenced construction site. These calculations were submitted in response to my letter dated December 5, 2011, indicating that the post-construction best management practice plan did not meet the requirements of the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC04893*AG. In particular, my letter indicated that the Water Quality Volume (WQv) provided within Detention Basin 3 was insufficient to meet requirements.

Upon review of the calculations, I discovered that I had made two errors which lead me to miscalculate the WQv storage provided by Detention Basin 3. As such, my letter was sent in error and the purpose of this letter is to correct that mistake. I can now concur that post-construction water quality requirements for this project are met by installing Outlet Structure OS3 in Detention Basin 3 as depicted in Detail 4 on Sheet C208 of the construction plans. No additional amendments to the post-construction BMP plan are required to comply with the NPDES permit.

AARON THOMPSON
ROB MISUTKA
DECEMBER 9, 2011
PAGE 2

I apologize for any inconvenience my error may have caused. Once you confirm that OS3 is installed per plan and all detention basins are configured for their post-construction function, I will inform our Central Office to terminate NPDES permit coverage.

If you have any questions, please contact me at (330) 963-1145.

Sincerely,



Dan Bogoevski
District Engineer
Division of Surface Water

DB:bo

pc: Bob Metze, The JM Smucker Co
Lynn Snyder, Engineer, Village of Orville (c/o Engineering Associates)
David Handwerk, Mayor, City of Orrville
Steve Wheeler, Public Service and Safety Director, City of Orrville

ec: Michael Joseph, DSW, CO