



**Environmental  
Protection Agency**

**John R. Kasich, Governor**

**Mary Taylor, Lt. Governor**

**Scott J. Nally, Director**

December 14, 2011

RE: CARROLL COUNTY  
VILLAGE OF MALVERN  
BTM SEWER DISTRICT  
20 WEST CANAL STREET  
PERMIT NO. 3PB00102

Carroll County Commissioners  
119 S. Lisbon St. Suite 201  
Carrollton, OH 44615

Dear Ladies and Gentlemen:

On November 30, 2011, this writer conducted a compliance evaluation inspection (CEI) at the BTM Sewer District Wastewater Treatment Plant (WWTP). The plant is located at 620 West Canal Street and discharges to Sandy Creek. At the time of the inspection, the plant appeared to be operating satisfactorily.

A review of the monthly operating reports for March 2011 through October 2011 revealed one pH violation of the National Pollutant Discharge Elimination System (NPDES) permit during that time.

At the time of the inspection, the following observations and comments were noted:

- 1) All treatment units were in operation. The aeration tanks had good color. The settling tanks appeared to be producing a satisfactory effluent. One of the clarifiers was idle.
- 2) One settling tank was idle at this time since it was not needed. The sand filters were operating satisfactory. The final effluent appeared satisfactory.
- 3) Sludge is disposed of by land application. At that time, the sludge tanks were approximately seventy percent full and the staff was in the process of removing sludge from the plant.

Should you have any comments or concerns regarding this letter, please feel free to contact me at (330) 963-1138.

Respectfully,

Joseph E. Trocchio, P.E.  
Environmental Engineer  
Division of Surface Water

JET/cs

cc: Ralph Castellucci, Superintendent, BTM Sewer District