



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 9, 2011

Douglas K. Browell
Village of Obetz
4175 Alum Creek Drive
Obetz, OH 43207

Re: Obetz Community Center / Franklin County

Dear Mr. Browell:

This letter is regarding the storm water inspection that I conducted at the Obetz Community Center, located at 4175 Alum Creek Drive, on December 7, 2011. ***It appears construction has not started at this site.*** The Ohio EPA has received and approved this site for coverage under the General Storm Water Permit associated with Construction Activities. Ohio EPA's Storm Water Staff will be conducting future storm water inspections to ensure compliance with the General Permit.

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Gregory Sanders, DSW/CDO

GS/nsm Obetz Community Center, December 7, 2011