



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

December 6, 2011

Steve Peck  
Dominion Homes  
5000 Tuttle Crossing Boulevard  
Dublin, OH 43016

**Re: Storm Water Inspection at Reynolds Crossing, Section 2 / Franklin County  
Permit #: 4GC03549\*AG**

Dear Mr. Kletrovetz:

This letter is written in follow-up to a construction storm water inspection I conducted at Reynolds Crossing Section 2 located in Reynoldsburg, Ohio on November 15, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls**

- The perimeter controls associated with the newest phase of development requires maintenance (SEE ATTACHED PHOTO).
- All barren areas must be protected in preparation for the upcoming winter months. Given the time of year, a crimped straw mulch cover or equivalent is expected. This directly applies to all barren areas including the large stockpile.

**Post Construction:**


- Please indicate in your response what post construction measures a utilized for this section.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Reynolds Crossing Sec 2 11-15-2011



Perimeter controls failing