



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

December 6, 2011

Matt Foor  
Performance Training School  
7791 Taylor Road  
Pataskala, Ohio 43068

**Re: Construction Storm Water Inspection at Performance Training School  
7791 Taylor Road, Pataskala, Ohio  
Permit Number 4GC033631\*AG**

Dear Mr. Foor:

This letter is written in follow-up to a construction storm water inspection I conducted at Performance Training School located at 7791 Taylor Road, in Pataskala, Ohio on November 15, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

**Winter Rule:**

- All barren and idle areas, specifically the entire site, must be protected in preparation for the upcoming winter months. Given the time of year, a crimped mulched cover, or equivalent, is expected.

**Sediment Controls:**

- During the inspection, it appeared the site was void of effective sediment controls. It was my understanding that a centralized sediment basin would be utilized for sediment control. Please be able to ensure all affected areas are routed to the basin intended for sediment control via earthen diversions.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Performance Training School 11-15-2011

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)