



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 2, 2011

Terry Feder
Hanson Pipe & Products, Inc.
1500 Haul Road
Columbus, OH 43207

**Re: Hanson Pipe & Products / Franklin County
Permit Number: 4GR00321*DG**

Dear Mr. Feder:

This letter is written in follow-up to an industrial storm water inspection I conducted on November 29, 2011, at Hanson Pipe and Products, Inc. located 1500 Haul Road, in Columbus, Ohio. I understand this facility is currently covered under the General Storm Water Permit associated with industrial activities. Based on my site observations and the conditions of the permit, the following items were noted:

Your Storm Water Pollution Prevention Plan (SWP3) and Spill Prevention Control and Countermeasure (SPCC) Plan are up-to-date and reviewed annually.

Your facility contains the storm water on-site and it is allowed to soak into the ground. There is an underground storm pipe that collects, stores and allows the storm water to drain into the ground. There is no point discharge from the storm water pipe. Storm water does not discharge from the site. Your facility is surrounded by a large berm on the west side and elevated railroad tracks on the east side. There are large ponds to the south.

There was a large dual-walled fuel tank on-site. There was no staining on the ground around the tank. There was a spill kit located next to the fuel tank.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Geoff Richardson, Hanson Pipe & Products

ec: Greg Sanders, DSW/CDO

GS/nsm Hanson Pipe & Products, November 29, 2011